

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. TN00125ERD00395

Dated: 28.06.2025

It is certified that an inspection team headed by P. JEYSANKAR Block Health Supervisor

(Name of Officers with designation) from GPHC, P. Puliyampatti PHED

inspected the AKSHARAM WORLD SCHOOL, 256/3 Madhampalayam, P. Puliyampatti

(Name & Address of the school) on 13.06.2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. GILCS/TR03691/2025-26 dated 17.06.2025

of GLOBAL LAB & CONSULTANCY SERVICES LTD (PHED Lab) certified that

the AKSHARAM WORLD SCHOOL (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 27.06.2026

AKSHARAM WORLD SCHOOL
To S.F.No. 256/3, Melthupalayam Road,
Madhampalayam Panchayat,
P. Puliyampatti, Erode - 638459.
(Name & Address of the Institution)

Signature with Seal: [Signature]
Name: P. JEYSANKAR
Designation: Block Health Supervisor
Name & Address of the Office / Department: [Address]

செல்லு கனத்தா குடிநீர் கட்டுப்பாட்டு
கமிஷனரின் அலுவலகம்
அரசு ஆரம்ப கனத்தா நிலையம்
முத்து. புலியம்பட்டி, எரோடு.

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

The above said seal is in the English
Version in S/d. P. JeySankar, Block Health Supervisor, Government
Primary Health Centre, P. Puliyampatti, Erode and Attested.

67 | Page



Sivaku
mar A

Digitally
signed by
Sivakumar A
Date:
2025.08.08
02:37:12
+05'30'

T. GANESAN, M.B.A., B.L.,
ADVOCATE, E.No. Ms. 2049 / 2003
NOTARY PUBLIC (GOVT. OF INDIA)
43-B, RAJA STREET,
ERODE DT., TAMILNADU.

CELL : 94424 07389



GOVERNMENT OF TAMIL NADU

DIRECTORATE OF PUBLIC HEALTH AND PREVENTIVE MEDICINE

பொது சுகாதாரம் மற்றும் நோய்த் தடுப்பு மருந்துத்துறை

SELF DECLARED SANITATION CERTIFICATE

(Issued under G.O.(Ms)No. 276 of Health and Family Welfare (AB2) Department dated

23.09.2024 on the basis of affidavit by the applicant)

Certificate Number : TN00125ERD00395

Issued Date : 28-06-2025

Organization Type : Educational Institutions

Expiry Date : 27-06-2026

Name of the Organization : AKSHARAM WORLD SCHOOL

Address : S.F No 256/3, Madhampalayam, P.Puliampatti - Erode - 638459

I, SIVAKUMAR A owner/manager of the AKSHARAM WORLD SCHOOL functioning as Educational Institutions located at Punjai Puliampatti in Erode district hereby declare that

- This Self-Declared Sanitation certificate is valid from 28-06-2025 to 27-06-2026 and will be renewed every year prior to the expiry of the current certificate with updated information.
- Our premises can accommodate 700 people/pupils and has 47 urinals and 47 toilets which is proportionate to the number of users as per government norms
- 5 Sanitation workers are deployed to clean the entire premises including Toilets, Common Area Spaces, etc., at regular intervals and proper record is maintained.
- The waste generated on our premises is properly processed and disposed of as per Solid Waste management Rules, 2016.
- There is no potential mosquito breeding area on the premises
- The premises have adequate drinking water fountains on each floor of the premises.
- The self-declared certificate is displayed prominently on the premises along with the protocol

The Government reserves the right to inspect at any point of time and cause for rectification or cancel or suspend the certificate and take legal action if any conditions are violated.



AKSHARAM WORLD SCHOOL

S.F.No. 256/3, Mettupalayam Road,

Madhampalayam Panchayat,

P. Puliampatti, Erode - 638459.

**Sivaku
mar A**

Digitally signed

by Sivakumar A

Date:

2025.08.08

02:37:27 +05'30'

Signature of the Owner/Manager



(அ) TN00125ERD00395 என்ற தனிப்பட்ட சான்றிதழ் எண்ணை

<https://www.tnsevai.tn.gov.in/edistrict/CheckStatus/Certificate/> ல் உள்ளிடு செய்து சரிபார்க்கவும்.

(அல்லது)

(ஆ) கைப்பேசியில் பார்கொடு படிப்பான் மூலம் இணையதளத்தில் சரிபார்க்கவும்.

Genuineness of the certificate can be verified by.

(a)Keying in the unique certificate number TN00125ERD00395 in the URL.

<https://www.tnsevai.tn.gov.in/edistrict/CheckStatus/Certificate/>

(or)

(b)Reading the 2D barcode with mobile barcode reader and verify through online.



Scan for Certificate

TEST REPORT

ULR-TC606025000007363E

Report Number : GLCS/TR03691/2025-26

Report Date : 17-06-2025

Issued To :	AKSHARAM WORLD SCHOOL S.F NO : 256/3, Mettupalayam Road, Madhampalayam panchayat, P.Puliampatti, ERODE 638459		
Attention	-	Sample Receipt Condition	Good
TRF No.	TRF/1137/2025-26	Sample Quantity	1.0 l
Sample Name	RO WATER	Sampled By	Customer
Sample Description	Liquid	Sampling Method	-
Sample Code	GLCS/03691/2025-26	Date of Analysis	13-06-2025
Sample Receipt Date	14-06-2025	Date of Completion	17-06-2025

Sl.No	TEST PARAMETER	TEST METHOD	UNITS	RESULT	LIMITS	
					Acceptable Limits	Permissible Limits
1	Calcium as Ca	IS 3025 (Part 40) (EDTA Titrimetric Method): 1991(Reaffirmed 2019)	mg/l	1.6	Max 75	200
2	Chloride as Cl-	IS 3025 (Part 32) (Argentometric Method): 1988(Reaffirmed 2019)	mg/l	8.0	Max 250	1000
3	Color	IS 3025 (Part 4): 2021	CU	<1	Max 5	15
4	Electrical Conductivity	IS 3025 (Part 14): 2013(Reaffirmed 2019)	µS/cm	108	-	-
5	Iron as Fe	IS 3025 (Part 53) (1,10 Phenanthroline Method): 2024	mg/l	BDL(DL: 0.1)	Max 1.0	No Relaxation
6	Magnesium as Mg	IS 3025 (Part 46) (EDTA Titrimetric Method): 2023	mg/l	2.9	Max 30	100
7	Odor	IS 3025 (Part 5): 2018	-	Agreeable	Agreeable	Agreeable
8	pH	IS 3025 (Part 11): 2022	-	6.20	6.5 - 8.5	No Relaxation

Note : BDL - Below Detection Limit, DL - Detection Limit, Max - Maximum, Limits - Limits as per IS 10500: 2012 Amd No.4 - Nov2021 Drinking Water Specification.



Page 1 of 2

For Global Lab and Consultancy Services LLP

Authorised Signatory
L.Sudha Priya
Technical Manager

Sivakumar A
Digitally signed by Sivakumar A
Date: 2025.08.08 02:37:45 +05'30'

Principal
AKSHARAM WORLD SCHOOL
S.F.No. 256/3, Mettupalayam Road,
Madhampalayam Panchayat,
P. Puliampatti, Erode - 638459.

Note: The test results are only to the sample submitted for test. Any Correction of the test report on full or part shall invalidate the report. Samples are not drawn by us unless otherwise stated. Sample will be retained for 15 days from the date of reporting except in case of regulatory samples or specifically instructed by client. Perishable samples will be discarded immediately after reporting. We do not accept any liability with regard to origin or source from which the samples are extracted. The Laboratory is not responsible for authenticity of photocopied test reports. Any holder of this report is advised that information contained here on reflects the laboratory's finding at the time of its intervention only and within the limits of client instructions. The authenticity of the test reports issued by us can be verified by submitting on E-mail request with report number and report date along with report copy.



Scan for Certificate

TEST REPORT

ULR-TC606025000007363F

Report Number : GLCS/TR03691/2025-26

Report Date : 17-06-2025

Issued To :	AKSHARAM WORLD SCHOOL S.F NO : 256/3, Mettupalayam Road, Madhampalayam panchayat, P.Puliampatti, ERODE 638459		
Attention	-	Sample Receipt Condition	Good
TRF No.	TRF/1137/2025-26	Sample Quantity	1.0 l
Sample Name	RO WATER	Sampled By	Customer
Sample Description	Liquid	Sampling Method	-
Sample Code	GLCS/03691/2025-26	Date of Analysis	13-06-2025
Sample Receipt Date	14-06-2025	Date of Completion	17-06-2025

Sl.No	TEST PARAMETER	TEST METHOD	UNITS	RESULT	LIMITS	
					Acceptable Limits	Permissible Limits
9	Potassium as K	IS 3025 (Part 45) (Flame Photometric Method): 1993(Reaffirmed 2019)	mg/l	1.99	-	-
10	Sodium as Na	IS 3025 (Part 45) (Flame Photometric Method): 1993(Reaffirmed 2019)	mg/l	16.71	-	-
11	Sulphate as SO4	IS 3025 (Part 24) SECTION 1: 2022	mg/l	3.83	Max 200	400
12	Total Alkalinity as CaCO3	IS 3025 (Part 23) (Titrimetric Method): 2023	mg/l	24.1	Max 200	600
13	Total Dissolved Solids (TDS)	IS 3025 (Part 16): 2023	mg/l	62	Max 500	2000
14	Total Hardness as CaCO3	IS 3025 (Part 21) (EDTA Titrimetric Method): 2009(Reaffirmed 2019)	mg/l	16.0	Max 200	600
15	Turbidity	IS 3025 (Part 10) (Nephelometric Method): 2023	NTU	<1	Max 1.0	5

Note : BDL - Below Detection Limit, DL - Detection Limit, Max - Maximum, Limits - Limits as per IS 10500: 2012 Amd No.4 - Nov2021 Drinking Water Specification.



Page 2 of 2

*****End of Report*****

For Global Lab and Consultancy Services LLP

Authorised Signatory
L.Sudha Priya
Technical Manager

Principal

Sivakumar A
Digitally signed
by Sivakumar A
Date:
2025.08.08
02:38:04 +05'30'

AKSHARAM WORLD SCHOOL
S.F.No. 256/3, Mettupalayam Road,
Madhampalayam Panchayat,
P. Puliampatti, Erode - 638459.

Note: The test results are only to the sample submitted for test. Any Correction of the test report on full or part shall invalidate the report. Samples are not drawn by us unless otherwise stated. Sample will be retained for 15 days from the date of reporting except in case of regulatory samples or specifically instructed by client. Perishable samples will be discarded immediately after reporting. We do not accept any liability with regard to origin or source from which the samples are extracted. The Laboratory is not responsible for authenticity of photocopied test reports. Any holder of this report is advised that information contained here on reflects the laboratory's finding at the time of its intervention only and within the limits of client instructions. The authenticity of the test reports issued by us can be verified by submitting on E-mail request with report number and report date along with report copy.